DN 75X300 Rainwater Outlet (Chameleon)



位力高試驗中心有限公司 CASTCO TESTING CENTRE LTD.

香港粉嶺安居街33號 33 Or Kui St eet, Fanling, Hong Kong. Tel: 2677 2138 香港粉嶺安全街29A號 79A, Chance Street, Fanling, Hong Kong. Fax: 2677 035 E-mail: castco@netvigator.com v.'ebsite. w.w.cr stco.com.hk



Test Report

Dimension check on discharge and ventilating pipes and fittings, and-cast or spun in cast iron

(Based on BS416: Part 1: 1990, Clause 4)

Date of issue: 12 November 2015

Page 1 of 1 page(s)

Cast o LRN: DP0150923-232 DIM

Customer's ref. no.: --

Details as supplied by customer

Customer: Cheung Hing Foundr, (HK) Limited

Address: 299 Pak Sha Tsuen, Kung Uni Road, Yuen Long, NT, HK

Contract no.: --

Job title: --

Sample description: DN75 x 300 H Rainwater Outlet with (SS316 cr C I.) Dome / Flat Crating "Chameleon"

Manufacturer: Cheung Hing Foundry (HK) Limited

rand: CHF-

Remark: --

Laboratory test result


Date sam le received: 23 September 2015

D' nensions Check

s pecimen no. : D' 0150923-232

Da e of test: 07 October 2015

Divensions	BS requirement from figure 20	Product requiremer. from code no	Measured mean value
21	/	180 mm	120 mm
D2		18% mm	181 mm
D3		2 · 0 i im	245 mm
D4		26.5 mm.	267 mm
Н		300 mm	295 mm
H1	//	30 mm	80 mm
H2	/ 〈	0 mm	9.83 mm
НЗ		25 mm	25 mm
DN	≥74 mm	75 mm	75 mm



Remarks:

- 1. Test result relates only to the specimen tested.
- 2. Compliance of the test results to the specification is an opinion of the lal oratory and is not covered under the HOKLAS accreditation.
- 3. Test results of the sample comply with the requirement of BS416: Part 1: 1990, Clause 4.

Che :ker. by :

SIT KWAN NING

Approved Signatory:

End of Report

1111.00019

F rm No. PIPE DIN 416 7 3 dd 20/08/2015

/11 Item no. DP/0501

WONG KA MAN Laboratory Manager

DN 100X300 Rainwater Outlet (Chameleon)

CASTCO

香港粉嶺安居街33號

香港粉嶺安全街29A號

E-mail: info@castco.com.hk

走力高試驗中心有限公司 CASTCO TESTING CENTRE LIMITED

CASTCO TESTING CENTRE

73, fin Kui Streck, Fanling, Hong Kong. Tel: 2597 8300 29A, On Chi en Street, Fanling, Hong Kong. Fax: 2597 8390 Website: Www.c.stco.com.hk



ľ

Customer's ref. no.: --

Test Report

Dimension check on discharge and ventilating pipes and fittings, sand-cast or spun in cast iron

(Based of 3S416: Part 1: 1990, Clause 4)

Date of issue: 12 De cmber 2017

Page 1 of 1 page(s)

Castco LRN: DP0171010-038 DIM

Details as supplied by cusic mer

Customer: Cheang Hing Foundry (4K) Lanited

Address: 299 Pak Sha Tsuen, Kung Um Pord, Yuen Long, N.T. Hong Kong

Contract no.: --

Job title : --

Sample description: DN 200 x 300mm H Rainwater Outlet with (SS 16 or C.I., Dome/Flat Grating "Chameleon"

Manufacturer: Cheung Hing Foundry (HK) Limited

Brand: CHF

Remark: Sample Submitted by: Asia Development (HK) Ltd

Laboratory test result

Date sample received: 10 October 2017

D mensions Check
S pecimen no.: 1

Date of test: 06 De	ecember 2017
---------------------	--------------

Din.ansions	BS re juin ment from figi re	Product requirement from code not	Measured mean value
DN	_99mm	100mm	10)mm
T	5 (+0/-1.5)mm	(-0)	4.99mm
D1		1√0n m	180mm
D2		180.mm	180mm
D3		250mm	245mm
D4	- //	265mm	268mm
Н	- (\	350mm	301mm
H1		80mm	80mm
H2		5.nm	9mm
НЗ		25m n	25mm

D1 H2 D3 D4 H3

Remarks:

1. Test result relates only to the specimen tested.

2. Test results of the sample comply with the requirement of BS416: Part 1: 1990, Clause 4.

Checked by:

SIT KWAN NING Labora ory Supervisor Approved Signatory:

WONG KA MAN Senior Manager

Form No. P PE DIM41/ 1. 4d 20/08/2015

/189

Item no. DP/0501

End of Report

DN 150X300 Rainwater Outlet (Chameleon)

香港粉嶺安居街33號 香港粉嶺安全街29A號 E-mail: info@castco.com.hk

走力高試驗中心有限公司 CASTCO TESTING CENTRE LIMITED

33, 6n Kui street, Fanling, Hong Kong. 29A, On Chi en Street, Fanling, Hong Kong. We bsite: www.c.istco.com.hk

Tel: 2597 8330 Fax: 2597 8399

Customer's ref. no.: --



Test Report

Dimension check on discharge and ventilating piper and fittings, sand-cast or spun in cast iron

(Based on '3S416: Part 1: 1990, Clause 4)

Date of issue: 12 December 2017

Page 1 of 1 page(s)

Castco LRN: DP0171010-039 DIM

Details as supplied by customer

Customer: Chearg Hing Foundry (HK) Lucited

Address: 299 Pak Sha Touen, Kung Um Pord, Yuen Long, N.T. Hong Kong

Contract no.: --

Job title: --

Sample description: DN150 x 300mm H Rainwater Outlet with (SS 16 or C.I., Dome/Flat Grating "Chameleon"

Manufacturer: Cheung Hing Foundry (HK) Limited

Brand: CHF

Remark: Sample Submitted by: Asia Development (HK) Ltd

Laboratory test result

Date sample received: 10 October 2017

D mensions Check Specimen no.: 2

Dale of test: 27 November 2017

Dimensions	BS re juin ment from figi re	Product requirement from code not	Measured mean value
DN	150mm	150mm	151mm
T	5 (+0/-1.5)mm	(-0)	4.97mm
D1		21/5n m	225mm
D2		225.nm	225mm
D3		295mm	295mm
D4	- //	32onm	320mm
Н	- (<	300mm	305mm
H1		105mm	105mm
H2		12mm	12mm
Н3		27m n	27mm

Remarks:

1. Test result relates only to the specimen tested.

2. Test results of the sample comply with the requirement of BS/16: Part 1: 1990, Clause 4.

Checked by:

SITKWAN NING Lat orat bry Supervisor

Approved Signatory:

End of Report

1. dd 20/08/201:

Item no. DP/0501

WONG KA MAN Senior Manager