

150 BS EN 877 Coupling 1

CASTCO

佳力高試驗中心有限公司
CASTCO TESTING CENTRE LTD.

香港粉嶺安居街33號 33, On Kui Street, Fanling, Hong Kong. Tel : 2677 2138
香港粉嶺安全街29A號 29A, On Chun Street, Fanling, Hong Kong. Fax: 2677 0351
E-mail: castco@netvigator.com Website: www.castco.com.hk



Test Certificate

Dimensions of Cast Iron Joints (BS EN 877 : 1999 Clause 5.8.1)

Date of issue : 03 May 2012

Page 1 of 1 page

Castco LRN : DP0120419-057 JD

Details as supplied by client

Client : Cheung Hing Foundry (HK) Limited

Client's ref. no. : --

Job title : --

Contract no. : --

Sample description :-

Sample I.D. : --

Type : Stainless Steel Coupling (Single screw)

Nominal size (DN) : 150

Manufacturer : Cheung Hing Foundry (HK) Limited

Brand : CHF 

Laboratory test results

Date sample received : 19 April 2012

Date of test : 23 April 2012



Dimension	Quoted dimension (mm)	Mean of measurements (mm)
W	54 (±0.5)	54.3

Effective width of sealing zone = 26 mm

- Remarks :
1. Test result relates to specimen tested.
 2. Compliance of the test results to the specification is an opinion of the laboratory and is not covered under the HOKLAS accreditation.
 3. Test result complies with BS EN 877 Cl. 4.7.2.

Checked by :

K.M. WONG

Approved Signatory :

End of Report

CHOI TZE WING
C. Eng., MHKIE, MICE
Quality Manager

Form No. PIPE D-877T dd 01/06/2007

Item no. DP/0611a

150 BS EN 877 Coupling 2

CASTCO**佳力高試驗中心有限公司
CASTCO TESTING CENTRE LTD.**

香港粉嶺安居街33號 33, On Kui Street, Fanling, Hong Kong. Tel : 2677 2138
香港粉嶺安全街29A號 29A, On Chun Street, Fanling, Hong Kong. Fax: 2677 0351
E-mail: castco@netvigator.com Website: www.castco.com.hk

**Test Certificate**

Visual Inspection of Marking of Cast Iron Pipes and Fittings, their Joints and Accessories
(BS EN 877 : 1999 clause 5.11)

Date of issue : 02 May 2012

Page 1 of 1 page

Castco LRN : DP0120419-057 MARK

Details as supplied by client

Client : Cheung Hing Foundry (HK) Limited

Client's Ref. No. : --

Job Title : --

Contract No. : --

Sample Description :-

Sample I.D. : --

Type : Joint

Nominal size (DN) : 150

Nominal length : 54 mm

Brand : CHF 

Manufacturer : Cheung Hing Foundry (HK) Limited

Laboratory test results

Date sample received : 19 April 2012

Date of test : 23 April 2012

Legible and indelible marking are found for :

(a)	Manufacturer's name or mark	Yes
(b)	Identification of production site	No
(c)	Period of manufacture, coded or not	No
(d)	Reference to BS EN 877 : 1999	No
(e)	DN	Yes
(f)	Design angle of fittings	N.A.
(g)	Identification of accredited third party where applicable	No

Remarks :-

1. Test result relate only to the specimens tested.
2. Compliance of the test results to the specification is an opinion of the laboratory and is not covered under the HOKLAS accreditation.
3. Test result complies with clause 4.10 of BS EN 877 : 1999.

Checked by : **K.M. WONG**Approved Signatory : **End of Report**

Item no. DP/0613

CHOI TZE WING
C. Eng., MHKIE, MICE
Quality Manager

Form No. : F-Pipe-Mark T dd 01/06/2007